

# Accessible Venue Checklist



Date of review: 12/28/21

Community Partner Name: Parks and Recreation of KC

Venue: Garrison Community Center

1124 E. 5th St., Kansas City, MO

## PARKING:

- Adequate Accessible Parking - **Yes**
- Parking Lines, Accessible Symbol, and Hash Marks Clear and in Good Condition- **Yes**
- Pavement in good condition. No significant cracks or other obstacles for wheelchairs, walkers, or other mobility devices. - **Yes**

## ENTRANCE:

- No-Step Entrance- **Yes**
- Entry Width Minimum 36" - **Yes**
- Walkway, gradient no greater than 1:20 (5%)- **Yes**
- Ramps, gradient no greater than 1:15 (6.6%)- **Yes**
- Exertion to Open Door Maximum of 10lbs Pressure- **Yes**
- Entry Contrast for Visibility- **Not Sure**
- Minimum 25 sq ft space (landing) outside entry door. Landing shall measure a minimum of 48" on one side and be clear of obstructions and door swing. Square footage requirement is for landing, not including square footage of access walk or ramp. Landing shall be level, allowing for positive drainage away from entry. - **Yes**

## COMMON SPACE:

- Main Walkways Width Minimum 42" - **Yes**
- Secondary Walkways (Between dining tables, clothes racks, etc.) Width Minimum 36" - **Yes**
- Transaction Space (Register, Sign In, etc.) Height Maximum 36" - **Yes**
- Hallways Width Minimum Unobstructed Width 42" - **Yes**
- Menus available in large print and Braille. (Can we offer to print for a fee?) - **Not Sure**
- All changes in path or obstacles designated with contrasting color for people with low vision. - **Yes**

## RESTROOMS:

- Entry Minimum 36" (32" if architecturally necessary) - **Yes**
- Exertion to Open Door Maximum of 5lbs Pressure- **Yes**
- Clear Floor Space of 30" by 40" Beside Toilet- **Yes**
- Comfort Height, ADA Compliant Toilet- **Yes**
- Adequate Grab Bars for Toilet- **Yes**
- Unobstructed Path to Restrooms- **Yes**
- Easily Recognizable Signage- **Yes**
- Door for Stall able to be open and closed with mobility device within the stall- **Yes**
- Sinks, Soap, and Paper Towels Accessible- **Yes**

## LIGHTING AND ACOUSTICS:

- Lighting adequate for people with low vision. - **Yes**
- Acoustics in the space and volume of any music allows people that are hard of hearing to hear the people in their group. - **Not Sure** – *Practice will be held in a gym, so members will need to be near coordinator to hear*